





Industrie Service

Mehr Sicherheit.  
Mehr Wert.

## Test Report: Containment Systems

Client	Blobel Umwelttechnik GmbH Henleinstrasse 29a 86368 Gersthofen, Germany
Test objects	Designation: <b>Containment systems / Retention barriers</b> (Category 1: Manual, mobile, slide-insert) Designation (dimensions): Type BL/BTL (250x30) Designation (dimensions): Type BL/BST (250x30)
Order	Participation in the leak testing of mobile containment systems for firefighting water retention based on VdS Guidelines 2564-1
Test result	Leaktightness Type BL/BTL: <b>0 ml/m/h</b> (< 50 ml/m/h) Leaktightness Type BL/BST: <b>0 ml/m/h</b> (< 50 ml/m/h)
Authors/contact	Dipl.-Ing. Martin Beike
Project number	1180345-K1-10 / 2931886
Test date	22 December 2017 and 16 August 2018
Report completion	16 November 2018
Scope of report	3 pages
Type BL/BTL	Type BL/BST



Date: 16 November 2018  
Reference: IS-BT1-MUC/Bm

Document: 1180345-K1-10\_BTG\_Fa  
Blobel\_Pruefung-Dichtheit\_Stoerfallsysteme\_TYPE N BTL\_EN.docx

The document consists of 4 pages.  
Page 1 of 4

Reproducing excerpts from this document and use for advertising purposes require the written consent of TÜV SÜD Industrie Service GmbH.

Die Prüfergebnisse beziehen sich ausschließlich auf die untersuchten Prüfgegenstände.





## 1 Basis

With the letter dated 18 July 2018, TÜV SÜD Industrie Service GmbH (TÜV SÜD) was engaged by Blobel Umwelttechnik GmbH, Henleinstrasse 29a, 86368 Gersthofen, Germany as follows: Participation in the leak testing of mobile containment systems for firefighting water retention based on VdS Guidelines 2564-1, dated October 2004.

## 2 Actions / Notes

On 22 December 2017 and 16 August 2018 measurement meetings with leak testing based on Chap. 5.8 of the VdS Guidelines 2564-1 took place in the factory hall-type buildings of Blobel Umwelttechnik GmbH. Once in the hall at Ziegelleistr. 5 and once at Henleinstrasse 29a each in 86368 Gersthofen, Germany.

The following systems were examined: Type BL/BTL and Type BL/BST.

Test sequence (based on Chap. 5.8 of the VdS Guidelines 2564-1):

- One-hour leak test

The following deviations from the leak test in accordance with Chap. 5.8 of VdS 2564-1 were found:

1. Substrate "Diamond height of 2 mm to DIN 59 220":

VdS 2564-1 specifies: "Diamond plate (checker plate) with a diamond height of 2 mm top DIN 59220 is used to simulate the substrate of the subsequent use conditions." The diamond height was 1.2 mm.

Products to DIN 59220 have a diamond (pattern) height of 1 mm to 2 mm. The question here is therefore whether the protection objective "leaktightness" to VdS 2564-1 really has to be verified for a diamond height of 2 mm or 1 mm to 2 mm, i.e. whether this is a transfer error from DIN 59220. To what extent a 2 mm, i.e. 0.8 mm higher diamond height than present actually influences the leaktightness test cannot be reliably foreseen without testing. But the diamond height used is standard and conforms to DIN 59220. The objective of the diamonds is to simulate the usual roughness of the substrate in the test. This is also achieved properly by a diamond height of 1.2 mm. The diamond height is therefore representative for different roughnesses.



## 2. Test period of the main test at least 4 h and at least 1 h for the repeat testing:

A test period of 1 h was chosen instead of 4 h. A repeat test was not performed. In this case the moisture penetration was observed and no significant time changes were found. The reduction in the test period is therefore justified.

## 3 Test result

Blobel Umwelttechnik GmbH had the following containment systems / retention barriers successfully tested with the following test result.

Category 1: “Manual system, mobile, slide-insert”	Test object Type	Test length / height [mm] / [mm]	Leak rate		Verification fulfilled
			Exist. [ml / m / h]	All. [ml / m / h]	
	<b>Type BL/BTL</b> Seal type DEP EPDM foam black / closed cell $\rho \approx 95 \text{ kg/m}^3$	2,500/300	0	50	yes
	<b>Type BL/BST</b> Seal Type DPV PVC foam, anthracite / closed-cell $\rho = 100\text{-}125 \text{ kg/m}^3$	2,500/300	0	50	yes

The test showed: the containment systems / retention barriers Type BL/BTL and Type BL/BST conform to the leaktightness based on Chap. 5.8 of VdS 2564-1.

Issued on 16 November 2018

TÜV SÜD Industrie Service GmbH  
Civil engineering Munich

Expert

gez.

gez.

Dipl. Ing. Martin Kneiβl

Dipl.-Ing. Martin Beike